

General Disclaimer

One or more of the Following Statements may affect this Document

- This document has been reproduced from the best copy furnished by the organizational source. It is being released in the interest of making available as much information as possible.
- This document may contain data, which exceeds the sheet parameters. It was furnished in this condition by the organizational source and is the best copy available.
- This document may contain tone-on-tone or color graphs, charts and/or pictures, which have been reproduced in black and white.
- This document is paginated as submitted by the original source.
- Portions of this document are not fully legible due to the historical nature of some of the material. However, it is the best reproduction available from the original submission.

(NASA-CR-169245) SOLAR THERMAL BENEFITS N82-30702
STUDY. TASK 1: UTILITY CASE STUDIES
(Science Applications, Inc.) 95 P CACL 10A Unclas
HC A05/MF A01 G3/44 28598

SOLAR THERMAL BENEFITS STUDY

PREPARED BY
SCIENCE APPLICATIONS, INC.

PREPARED FOR
JET PROPULSION LABORATORY
MARCH 1982
CONTRACT NUMBER 956106



9950-694

SOLAR THERMAL BENEFITS STUDY

TASK 1 - UTILITY CASE STUDIES

S. YOUNG, R. EDWARDS
SCIENCE APPLICATIONS, INC.
(703) 821-4495



TOPICS

- INTRODUCTION
- METHODOLOGY ISSUES
- SOLAR SYSTEM PERFORMANCE
- UTILITY SYSTEM DESCRIPTIONS
- FUEL AND ECONOMIC ASSUMPTIONS
- SOLAR SYSTEM BENEFITS RESULTS
- REMAINING WORK



OBJECTIVE

- EVALUATE BENEFITS OF SOLAR THERMAL ELECTRIC SYSTEMS IN THE UTILITY SECTOR

APPROACH

- SELECT REPRESENTATIVE CASE STUDIES
- PERFORM VALUE ANALYSIS OF SOLAR THERMAL SYSTEMS
- SUMMARIZE SOLAR THERMAL SYSTEM VALUE, BREAK-EVEN COSTS, MARGINAL BENEFITS CURVE
- PERFORM SELECTED SENSITIVITY ANALYSES



CASE STUDIES SCOPE

- SOLAR TECHNOLOGIES
 - CENTRAL RECEIVER, SALT CONFIGURATION, NO STORAGE
 - COST GOAL PERFORMANCE ASSUMPTIONS
- FUEL COSTS
 - NEP-3 PROJECTIONS WITH EIA REGIONALIZATION
 - HIGH, MEDIUM, LOW
- UTILITIES/SITES
 - 3 INVESTOR-OWNED, 1 MUNICIPAL
 - GOOD TO MEDIUM INSOLATION (COLORADO, TEXAS, FLORIDA SITES)
- PENETRATION LEVELS
 - 2%, 5%, 10% PENETRATION
- ECONOMIC ASSUMPTIONS
 - SOLAR THERMAL COST GOALS
- ON LINE DATES
 - 1990, 2000



SELECTED UTILITY CHARACTERISTICS

- PUBLIC SERVICE COMPANY OF COLORADO (PSC)
 - 4074 MW (1990) - 350 HYDRO, 300 NUCLEAR, 1200 COAL, 950 OIL & GAS
 - SUMMER AND WINTER PEAKING (2665 MW AND 2513 MW IN 1978)
 - 5-6% PEAK DEMAND GROWTH (5% ASSUMED)
 - SIGNIFICANT HYDRO CAPABILITY
 - DIRECT INSOLATION 6.1 kWh/m²_D
- TEXAS UTILITIES (DALLAS POWER & LIGHT, TEXAS ELECTRIC, TEXAS POWER AND LIGHT)
 - 24,335 MW (1990) - COAL, NUCLEAR, GAS
 - SUMMER PEAKING (11,232 MW IN 1978)
 - 6% LOAD GROWTH (5% ASSUMED)
 - SIGNIFICANT GAS RELIANCE BUT CHANGING TO COAL
 - DIRECT INSOLATION 4.8 kWh/m²_D (SOLMET TMY, FORT WORTH)
- CITY OF AUSTIN ELECTRIC DEPARTMENT, TEXAS
 - 2015 MW (1990) - COAL, NUCLEAR (?), SIGNIFICANT GAS
 - SUMMER PEAKING (732 MW IN 1978)
 - 7% LOAD GROWTH (6% ASSUMED)
 - MUNICIPAL FINANCING
 - DIRECT INSOLATION 4.8 kWh/m²_D (SOLMET TMY, FORT WORTH)
- FLORIDA POWER CORPORATION
 - 7426 MW (1990) - COAL, NUCLEAR, OIL
 - SUMMER PEAKING (4135 MW IN 1978)
 - 5% LOAD GROWTH
 - DIRECT INSOLATION 4.4 kWh/m²_D (SOLMET TMY, APALACHICOLA)
 - SIGNIFICANT OIL RELIANCE BUT CHANGING TO COAL

DATA SOURCES



CATEGORY	SOURCE
SOLAR PLANT PERFORMANCE	SNLL FOR CR, JPL FOR PFDR
SOLAR WEATHER DATA	SOLMET TMY FOR FORT WORTH, APALACHICOLA ERSATZ TMY FOR DENVER WEST ASSOCIATES FOR 1978
UTILITY LOAD DATA	INDIVIDUAL UTILITY RECORDS
UTILITY PLANT TYPES AND SIZES	INDIVIDUAL UTILITY DATA SUBMITTED TO EIA
UTILITY PLANT HEAT RATES AND FORCED OUTAGE RATES	EII DATA FOR DIFFERENT PLANT TYPES AND SIZES, EPRI DATA
FUEL COSTS	NEP-III PROJECTIONS WITH EIA ARC REGIONALIZATION (JPL)
ECONOMIC ASSUMPTIONS	SOLAR THERMAL COST GOALS
LOAD GROWTH RATES	DOE/RELIABILITY COUNCIL PROJECTIONS





METHODOLOGY


SOLAR ELECTRIC POWER SYSTEMS IMPACTS ANALYSIS METHODOLOGY



SA

SOLAR THERMAL ELECTRIC PLANT PERFORMANCE MODEL

ORIGINAL PAGE IS
OF POOR QUALITY




*JPL SOLAR THERMAL
PROGRAM EMPHASIS

SA

FORMULATION OF UTILITY LOAD DURATION CURVES


DEMAND
(MW)

TYPICAL ONE-DAY LOAD PROFILE



TIME (HRS)

CORRESPONDING LOAD DURATION CURVE




PERCENT OF TIME

ORIGINAL PAGE IS
OF POOR QUALITY

SA

SCREENING CURVE ANALYSIS FOR CAPACITY OPTIMIZATION



ORIGINAL DESIGN
OF POOR QUALITY

SAI

CAPACITY ADJUSTMENT MODEL

LINEAR PROGRAM

OBJECTIVE: MINIMIZE PRESENT WORTH OF FIXED AND VARIABLE PLANT COSTS

CONSTRAINTS

- INSTALLED RESERVE MARGIN
- DEMAND REQUIREMENTS
- PLANT CAPACITY
- PLANT AVAILABILITY
- PLANT PURCHASE LIMITS


VARIABLES

- NUMBER OF PLANTS OF EACH TYPE
- PLANT DISPATCH AT EACH DEMAND LEVEL

ORIGINAL PAGE IS
OF POOR QUALITY

SA


LINEAR PROGRAMMING APPROXIMATIONS



SA

PRODUCTION COSTING

A. ANNUAL MAINTENANCE SCHEDULING



SA

TYPICAL MAINTENANCE SCHEDULE OUTPUT

WEEKS

PRODUCTION COSTING

B. SYSGEN PROBABILISTIC PRODUCTION COSTING

- SETS UP UNIT COMMITMENT ORDER BASED ON MARGINAL COST AND SPINNING RESERVE REQUIREMENTS
- TREATS UNSCHEDULED OUTAGES PROBABILISTICALLY
- USES BOOTH-BALERIAUX ALGORITHM: EACH GENERATOR SEES AN EFFECTIVE LDC WHICH COMBINES THE ORIGINAL LDC AND THE RANDOM OUTAGES OF EARLIER GENERATORS IN THE LOADING ORDER
- COMPUTES SUCCESSIVE LDC'S USING RECURSIVE NUMERICAL INTEGRATION



ECONOMIC ANALYSIS

- INPUTS INCLUDE TOTAL COST OF CONVENTIONAL GENERATION FOR BOTH SOLAR AND NO-SOLAR CASES
- THE VALUE OF SOLAR GENERATION IS THE DIFFERENCE BETWEEN SOLAR AND NO-SOLAR CONVENTIONAL COSTS
- THE PRESENT WORTH AND BREAKEVEN COST OF SOLAR IS CALCULATED BASED ON USER/OWNER FINANCIAL DATA

SA

ORIGINAL
OF



METHODOLOGY ISSUES

METHODOLOGY ISSUES

- LOAD SHAPE PROJECTION
 - CONSERVATION, STORAGE, EFFICIENCY
 - LOAD RANDOMNESS
 - WEATHER DEPENDENCE
- SOLAR SUBTRACTION
 - DETERMINISTIC VS. PROBABILISTIC
 - WEATHER DEPENDENCE
- CAPACITY EXPANSION AND PRODUCTION COSTING
 - DERATED UNITS VS. PROBABILISTIC OUTAGES
 - MAINTENANCE SCHEDULING
 - MULTIYEAR VS. SNAPSHOT YEAR
 - HYDRO, STORAGE
 - SYSTEM RELIABILITY
 - NUCLEAR STATUS
 - UNIT STARTUP, SHUTDOWN, SPINNING RESERVE
 - UNIT HEAT RATES, VALVE POINTS



CENTRAL RECEIVER SYSTEM DESCRIPTION



CENTRAL RECEIVER SYSTEM CONFIGURATION*

- SURROUNDING FIELD, 12040 HELIOSTATS, $.602 \times 10^6 \text{ m}^2$ COLLECTOR AREA, $2.2 \times 10^6 \text{ m}^2$ LAND AREA
- CAVITY RECEIVER, 566°C (1050°F) OUTPUT
- NITRATE SALT HEAT TRANSPORT FLUID
- 0.67 RATED COLLECTOR (FIELD AND RECEIVER) EFFICIENCY
- 538°C (1000°F) 1800 PSI REHEAT STEAM HEAT EXCHANGER
- RANKINE CYCLE TURBINE GENERATOR, .39 NET EFFICIENCY
- 381 MW_T AT BASE OF TOWER, 150 MW_e NET TURBINE OUTPUT (AT RATED CONDITIONS, $.95\text{kw/m}^2$ INSOLATION, NOON EQUINOX)

* REFERENCE: K. BATTLESON, "SOLAR POWER DESIGN GUIDE", SAND 81-8005, 1981.



CENTRAL RECEIVER DESIGN POINT EFFICIENCIES*

<u>LOSS MECHANISM</u>	<u>EFFICIENCY</u>	<u>CUMULATIVE EFFICIENCY</u>	<u>POWER</u>
INSOLATION	---	1.0	567 MW
HELIOSTAT RELIABILITY	.999	.999	
COSINE LOSSES	.856	.855	
REFLECTIVITY	.90	.769	
SHADOW, BLOCKING	1.0	.769	
TOWER SHADOW	1.0	.769	
ATMOSPHERIC ATTENUATION	.947	.729	
SPILLAGE	.988	.720	
RECEIVER ABSORPTION	.98	.706	
RADIATION, CONV., COND.	.955	.674	
PIPING	.998	.672	381 MW _T
GROSS TURBINE ELECTRIC	.43	.289	
NET TURBINE ELECTRIC	.91	.262	150 MWE
ELECTRIC TRANSMISSION	1.0	.262	
PLANT AVAILABILITY	.95	.249	

*DESIGN POINT: .95 kW/m² DIRECT INSOLATION, NOON EQUINOX IN FORT WORTH (SOLAR ELEVATION 57.2°), 20°C AMBIENT TEMPERATURE.



CENTRAL RECEIVER SIMULATION RESULTS

	FORT WORTH	DENVER
ANNUAL DIRECT NORMAL INSOLATION	1764 kWh/m ² -y	2212 kWh/m ² -y
ANNUAL SYSTEM EFFICIENCY	.202	.218
ANNUAL CAPACITY FACTOR	.163	.219
ANNUAL OUTPUT PER M ²	356 kWh _E /m ² -y	483 kWh _E /m ² -y
ANNUAL OUTPUT FOR 150 MWE SYSTEM*	214,400 MWh _E /y	287,500 MWh _E /y

NOTE: THE EFFICIENCIES AND OUTPUTS GIVEN ABOVE DO NOT INCLUDE FORCED OUTAGES.



UTILITY SYSTEM DESCRIPTIONS



UTILITY CAPACITY EXPANSION

- CAPACITY EXPANSIONS WERE DEVELOPED THROUGH 1990 AND 2000.
- GENERATION ADDITIONS ALREADY PLANNED BY THE INDIVIDUAL UTILITIES WERE INCORPORATED THROUGH 1990.
- ADDITIONAL EXPANSION PLANTS WERE NECESSARY PRIMARILY FOR YEAR 2000. (A FEW MINOR ADJUSTMENTS WERE MADE FOR 1990). ADDITIONAL NUCLEAR PLANTS WERE LIMITED.
- IN GENERAL, ALL OF THE UTILITIES EVALUATED HAD EXCESS PEAKING CAPACITY AND HAD IMMEDIATE PLANS FOR SUBSTANTIAL COAL PLANT ADDITIONS.



GENERATING PLANT CHARACTERISTICS FOR UTILITY EXPANSION

GENERATING UNIT	FUEL	HEAT RATE (BTU/MWH)	CAPITAL COST (\$/KW)	FIXED O&M (\$/KW/Y)	VAR O&M (\$/MWH)	FORCED OUTAGE RATE	SCHEDULED MAINTENANCE (WEEK/YEAR)
800 MW NUCLEAR (N)	N	10.40	960	3.25	0.82	0.15	7
800 MW COAL (WFGD)	COAL	8.31	960	2.82	2.76	0.24	5
800 MW NATURAL GAS (NG)	NG	9.2	450	2.25	0.37	0.24	5
600 MW NATURAL GAS	NG	9.4	450	2.25	0.37	0.21	5
400 MW NATURAL GAS	NG	9.5	450	2.25	0.37	0.13	5
600 MW COAL	COAL	9.167	1,000	2.32	2.76	0.21	5
400 MW COAL	COAL	9.27	1,070	2.82	2.76	0.13	5
400 MW OIL	OR*	9.40	450	2.25	0.37	0.13	5
200 MW NATURAL GAS	NG	10.05	450	2.25	0.37	0.074	3.5
200 MW OIL	OR*	9.90	450	2.25	0.37	0.074	3.5
200 MW COAL	COAL	9.785	1,190	2.82	2.76	0.074	3.5
50 MW CT	OD**	14.00	185	0.61	2.50	0.240	2

ORIGINAL COST IS
OF POOR QUALITY

*OR - OIL RESIDUAL

**OD - OIL DISTILLATE

SOURCE: 1979 EPRI TECHNICAL ASSESSMENT GUIDE, COSTS CONVERTED TO 1980 \$s.

NOTE: EXISTING UTILITY EXPANSION PLANS WERE USED THROUGH 1990.

CAPACITY ADDITIONS OVER AND ABOVE
CURRENT PLANS FOR TEXAS UTILITIES

ORIGINAL PAGE IS
OF POOR QUALITY

GENERATION TYPE	CUMULATIVE MW OF CAPACITY ADDED 1990	2000
NUCLEAR*	800	800
COAL	0	15,752
OIL PEAKING	0	0

* LIMITED TO ONE UNIT.

SAI

ORIGINAL DRAWING
OF POOR QUALITY

TEXAS UTILITIES
1990 BASE CASE EXPANSION (NO SOLAR)

PLANT TYPE	CAPACITY, MW	ENERGY, 10 ³ MWH/Y	LEVELIZED VARIABLE COSTS, M\$/Y
NUCLEAR	1693	14,952	232
COAL AND LIGNITE	10,172	61,227	958
GAS	12,498	21,005	1702
TOTAL	24,363	97,184	2892

SAI

CAPACITY ADDITIONS OVER AND ABOVE CURRENT
PLANS FOR PUBLIC SERVICE OF COLORADO

GENERATION TYPE	CUMULATIVE MW OF CAPACITY ADDED	
	1990	2000
NUCLEAR/HYDRO*	1600	3200
COAL	0	920
OIL PEAKING	0	460

* LIMITED TO CAPACITY SHOWN.

ORIGINAL PAGE IS
OF POOR QUALITY

SAI

PUBLIC SERVICE OF COLORADO
1990 BASE CASE EXPANSION (NO SOLAR)

PLANT TYPE	CAPACITY, MW	ENERGY, 10 ³ MWH/Y	LEVELIZED VARIABLE COSTS, M\$/Y
NUCLEAR, HYDRO	802	5201	78
COAL	3904	22,194	514
RESIDUAL OIL	263	84	10
DISTILLATE OIL	133	26	3
GAS	641	596	63
TOTAL	5743	28,101	671

ORIGINAL COSTS
OF POOR QUALITY

SAI

CAPACITY ADDITIONS OVER AND ABOVE
CURRENT PLANS FOR AUSTIN MUNICIPAL

ORIGINAL DRAWING
OF POOR QUALITY

GENERATION TYPE	CUMULATIVE MW OF CAPACITY ADDED	
	1900	2000
NUCLEAR*	50	1300
COAL	0	0
OIL PEAKING	0	0

* CURRENT PLANS CALL FOR SHARED OWNERSHIP OF NUCLEAR GENERATION;
THE ACTUAL CAPACITY SHARED WAS ALLOWED TO CHANGE OVER TIME AS
APPROPRIATE.

SAI


AUSTIN MUNICIPAL
1990 BASE CASE EXPANSION (NO SOLAR)

PLANT TYPE	CAPACITY, MW	ENERGY 10 ³ MMH/Y	LEVELIZED VARIABLE COSTS, M\$/Y
NUCLEAR	45	291	4
COAL	600	3897	117
GAS	1416	2777	218
TOTAL	2061	6965	339



ORIGINAL PAGE IS
OF POOR QUALITY

AUSTIN DAILY LOAD PROFILES



AUSTIN MUNICIPAL BASE CASE 1990 EXPANSION

ORIGINAL PAGE 15
OF POOR QUALITY

JPL UTILITIES ASSESSMENT, 1990, SULAM										SYSTEM MD			
PLANT TYPE	NUMBER OF UNITS	UNIT CAPACITY (MW)	UNIT COSTS (\$/KW)	TOTAL COST (1000\$)	FIXED CHARGE RATE	ANNUAL COST (1000\$)	FIXED O AND M (\$/KW)	ANNUAL FWD O/M (1000\$)	TOTAL FWD COSTS (1000\$)				
1.00C	1.0000	1170.00	52953.13	52953.13	-0.620	3283.09	5.25	237.52	3520.61				
100 MULEY STATION	1.0000	352.00	0.00	0.00	-0.096	0.00	0.00	0.00	0.00				
107 MULEY STATION	1.0000	436.00	0.00	0.00	-0.525	0.00	0.00	0.00	0.00				
108 MULEY STATION	1.0000	113.00	0.00	0.00	-0.068	0.00	0.00	0.00	0.00				
109 MULEY STATION	1.0000	113.00	0.00	0.00	-0.078	0.00	0.00	0.00	0.00				
110 MULEY STATION	1.0000	190.00	0.00	0.00	-0.084	0.00	0.00	0.00	0.00				
111 MULEY STATION	1.0000	212.00	0.00	0.00	-0.512	0.00	0.00	0.00	0.00				
112 MULEY STATION	1.0000	300.00	0.00	0.00	-0.536	0.00	0.00	0.00	0.00				
113 MULEY STATION	1.0000	300.00	0.00	0.00	-0.541	0.00	0.00	0.00	0.00				
TOTAL	1.0000	2061.25	52953.13	52953.13	0.00	3283.09	0.00	237.52	3520.61				
PLANT TYPE	NUMBER OF UNITS	UNIT CAPACITY (MW)	UNIT COSTS (\$/KW)	TOTAL COST (1000\$)	FUEL TYPE	FUEL COST (\$/MMB)	ANNUAL FUEL COST (1000\$)	ANNUAL VAR COSTS (1000\$)	ANNUAL MEV REUPTS (1000\$)				
1.00C	1.0000	29000.00	365.02	365.02	MUC	10.19	4126.74	4511.76	8032.37				
100 MULEY STATION	1.0000	172500.00	3763.95	3763.95	GAS	76.00	132623.10	136307.13	136307.13				
107 MULEY STATION	1.0000	42700.00	1005.95	1005.95	GAS	81.04	35003.40	36009.35	36009.35				
108 MULEY STATION	1.0000	25110.00	50.65	50.65	GAS	69.28	2116.37	2167.02	2167.02				
109 MULEY STATION	1.0000	15610.00	12.38	12.38	GAS	66.70	1353.42	1305.79	1305.79				
110 MULEY STATION	1.0000	57320.00	1207.73	1207.73	GAS	78.44	44960.89	46167.02	46167.02				
111 MULEY STATION	1.0000	111500.00	253.33	253.33	GAS	82.98	9252.05	9505.37	9505.37				
112 MULEY STATION	1.0000	201000.00	5129.66	5129.66	CUAL	29.93	60278.96	65000.02	65000.02				
113 MULEY STATION	1.0000	184200.00	4885.14	4885.14	CUAL	30.33	57390.00	62275.18	62275.18				
TOTAL	1.0000	1074920.00	16713.00	16713.00	0.00	0.00	347096.24	363010.00	367330.65				

AUSTIN MUNICIPAL SOLAR NET BENEFITS, 10% PENETRATION, 1990

DIFFERENTIAL EFFECTS JPL BENEFITS ASSESSMENT AND SOLAR JPL BENEFITS ASSESSMENT, 10% PENETRATION

PLANT TYPE	NUMBER OF UNITS	UNIT CAPACITY (MW)	UNIT COSTS (\$/KW)	TOTAL COST (\$1000)	FIXED CHARGE RATE	ANNUAL COST (\$1000)	FIXED O AND M (\$/KW)	ANNUAL F&O U/M (\$1000)	TOTAL F&O COSTS (\$1000)
166 UTILITY GEN	0.0000	352.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
167 UTILITY GEN	0.0000	436.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
168 UTILITY GEN	0.0000	113.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
169 UTILITY GEN	0.0000	113.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
170 UTILITY GEN	0.0000	190.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
171 UTILITY GEN	0.0000	212.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
172 UTILITY GEN	0.0000	300.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOTAL	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

PLANT TYPE	NUMBER OF UNITS	ANNUAL ENERGY (MWH)	UNIT COSTS (\$/MWH)	ANNUAL U AND M (\$1000)	FUEL TYPE	FUEL COST (\$/MWH)	ANNUAL FUEL COST (\$1000)	ANNUAL VAR COSTS (\$1000)	ANNUAL REV REBTS (\$1000)
166 UTILITY GEN	0.0000	8000.00	2.18	174.56	GAS	76.00	6150.64	6325.20	6325.20
167 UTILITY GEN	0.0000	5010.00	2.35	117.44	GAS	81.84	4100.23	4218.07	4218.07
168 UTILITY GEN	0.0000	352.00	2.02	6.70	GAS	88.20	279.82	286.52	286.52
169 UTILITY GEN	0.0000	210.00	2.07	4.52	GAS	86.70	189.01	193.53	193.53
170 UTILITY GEN	0.0000	5070.00	2.11	106.82	GAS	78.44	3976.76	4083.58	4083.58
171 UTILITY GEN	0.0000	11750.00	2.27	26.05	GAS	82.98	973.33	999.96	999.96
172 UTILITY GEN	0.0000	25000.00	2.54	54.39	COAL	30.33	697.66	757.04	757.04
TOTAL	0.00	22100.00	0.00	456.87	0.00	0.00	16367.45	16863.93	16863.93

OF POOR QUALITY

FLORIDA POWER CORPORATION

1990 BASE CASE EXPANSION (NO SOLAR)

PLANT TYPE	NUMBER OF PLANTS	CAPACITY, MW	ENERGY 10 ³ MWH/Y	LEVELIZED VARIABLE COSTS, M\$/Y
RESIDUAL OIL	33	3,883	2,249	305
DISTILLATE OIL	9	1,357	2,918	391
COAL	5	2,710	16,693	673
NUCLEAR	1	801	5,256	91
TOTAL	48	9,388	27,116	1,424



ECONOMIC ASSUMPTIONS
AND
FUEL COSTS



COST GOAL UTILITY FINANCIAL ASSUMPTIONS

BASE YEAR FOR ALL COSTS	1980
ONLINE YEAR	1990 OR 2000
INFLATION	5% BEYOND 1990
DEBT*	50% AT 3% REAL COST
PREFERRED EQUITY*	15% AT 3.5% REAL RETURN
COMMON EQUITY*	35% AT 6.5% REAL RETURN
WEIGHTED COST OF CAPITAL*	3.55% REAL, 8.73% NOMINAL
PLANT LIFETIME	30Y
TAX BRACKET**	50%
INVESTMENT TAX CREDIT**	10%
ANNUAL PROPERTY TAX, INSURANCE	2% (WITH NO INFLATION)
ANNUAL FIXED O&M	2%
DEPRECIATION**	15Y, DOUBLE DECLINING BALANCE (REAGAN POLICY)
CAPITAL COST ESCALATION	2% REAL, 7.1% NOMINAL
O&M ESCALATION	2% REAL, 7.1% NOMINAL

* MUNICIPAL ASSUMPTIONS ARE 60% DEBT AT 2% REAL COST AND 40% INTERNALLY GENERATED FUNDS AT 4% REAL COST, FOR A WEIGHTED COST OF CAPITAL OF 2.8% REAL, 7.9% NOMINAL.

** NOT APPLICABLE FOR MUNICIPAL UTILITY.

SAI

SOLAR PLANT OWNERSHIP ALTERNATIVES

- **SOLAR PLANT IS FINANCED ACCORDING TO OWNER'S FINANCIAL PARAMETERS**
- **SOLAR PLANT IS INTERACTIVE WITH THE UTILITY GRID**
- **SAVINGS TO THE UTILITY RESULTING FROM SOLAR ARE RETURNED TO THE OWNER (ASSUMES EQUITABLE DISTRIBUTION OF NET SAVINGS RESULTING FROM SOLAR)**
- **SOLAR BREAKEVEN COST TO THE OWNER THEREFORE DEPENDS ON BOTH OWNER'S AND UTILITY'S FINANCIAL ASSUMPTION AS WELL AS ON UTILITY GENERATION MIX, LOAD SHAPE, FUEL COSTS, PENETRATION LEVEL, ETC.**



SOLAR PLANT OWNERSHIP ALTERNATIVES FINANCIAL ASSUMPTIONS

	INVESTOR UTILITY	MUNI- CIPAL	FEDERAL	25% I.C.C.	INVESTOR BASE	50% LOAN	5 YR. DEPR	20% ROI
INVESTMENT PERIOD	30	30	30	20	20	20	20	20
DISCOUNT RATE	.0873	.079	.10	.15	.15	.15	.15	.20
LOAN FRACTION	0	0	0	0	0	.5	0	0
LOAN INTEREST RATE	-	-	-	-	-	.1	-	-
LOAN PERIOD	-	-	-	-	-	20	-	-
TAX BRACKET	.5	0	0	.5	.5	.5	.5	.5
DEPRECIATION METHOD	DDB	-	-	DDB	DDB	DDB	DDB	DDB
DEPRECIATION LIFE	15	-	-	10	10	10	5	10
PROPERTY TAXES, INSURANCE, ETC.	.02	.0125	.0025	.02	.02	.02	.02	.02
SOLAR PLANT O&M	.02	.02	.02	.02	.02	.02	.02	.02
O&M REAL ESCALATION	.02	.02	.02	.02	.02	.02	.02	.02
SOLAR TAX CREDIT	.10	0	0	.25	.10	.10	.10	.10
FCMULT*	.113	.0885	.0916	.151	.189	.120	.169	.244

ORIGINAL PAGE IS
OF POOR QUALITY

*FCMULT IS THE RATIO OF LEVELIZED ANNUAL SOLAR SYSTEM COST TO CAPITAL COST
(SIMILAR TO FCR BUT INCLUDES LEVELIZED O&M).

FUEL PRICE ASSUMPTIONS

	1990 FUEL PRICE IN 1980 \$/MBTU	ANNUAL REAL ESCALATION RATE, %/Y
DISTILLATE OIL	8.96	3
RESIDUAL OIL	8.11	3
NATURAL GAS	6.74	3
NUCLEAR	0.887	3
BITUMINOUS COAL	2.20	3
LIGNITE COAL	0.823	3

* PROVIDED BY JPL USING EIA DATA FOR THE SOUTHWEST ADJUSTED
BY NEP-111 WORLD OIL PRICES.



A NOTE ON LEVELIZATION

- COST GOALS COMMITTEE HAS BEEN USING NOMINAL DISCOUNT RATES FOR LEVELIZATION (E.G., FOR FUEL COSTS):

$$\text{CRF (D NOM)} = .095, N = 30) = .102$$

- SAI UTILITY METHODOLOGY USES REAL DISCOUNT RATES FOR LEVELIZATION:

$$\text{CRF (D REAL)} = .043, N = 30) = .060$$

- THUS, LEVELIZED VALUES IN SAI UTILITY CASE STUDY SHOULD BE MULTIPLIED BY $.102/.060 = 1.70$ TO YIELD COST GOAL LEVELIZED VALUES

- THE LEVELIZATION METHOD DOES NOT EFFECT THE RESULTING SOLAR SYSTEM BREAK-EVEN COSTS COMPUTED BY THE SAI METHODOLOGY



NOTE ON SOLAR PENETRATION LEVELS

- AS USED HERE, SOLAR PENETRATION LEVEL IN PERCENT
IS DEFINED AS:

(RATED MW OF SOLAR SYSTEMS INSTALLED BY ONLINE YEAR)

100 * (UTILITY PEAK LOAD MW IN ONLINE YEAR)



SOLAR SYSTEM BREAK-EVEN COST VERSUS REVENUE SAVINGS

ORIGINAL PAGE IS
OF POOR QUALITY

$$\left\{ \begin{array}{l} \text{BREAK-EVEN SOLAR} \\ \text{SYSTEM COST,} \\ \text{\$/kW} \end{array} \right\} = \frac{\left\{ \begin{array}{l} \text{LEVELIZED ANNUAL} \\ \text{REVENUE SAVINGS} \\ \text{TO THE UTILITY,} \\ \text{\$/kW/Y} \end{array} \right\}}{\left\{ \begin{array}{l} \text{FIXED COST} \\ \text{MULTIPLIER} \\ \text{FCMULT OF} \\ \text{THE OWNER,} \\ \text{Y}^{-1} \end{array} \right\}}$$

SAI


RESULTS FOR TEXAS UTILITIES



ORIGINAL PAGE IS
OF POOR QUALITY

LEVELIZED ANNUAL REVENUE SAVINGS PER UNIT SOLAR
SYSTEM kW FOR TEXAS UTILITIES, 1990 ONLINE DATE

LEVELIZED ANNUAL REVENUE SAVINGS



LEVELIZED ANNUAL REVENUE REQUIREMENTS PER UNIT SOLAR
SYSTEM kW FOR TEXAS UTILITIES, 1990 ONLINE DATE

COST ITEM	SOLAR PENETRATION LEVEL		
	2%	5%	10%
TOTAL	87	82	77
CAPITAL	0	0	0
O&M	4	4	4
COAL	7	7	8
GAS	72	67	61
RESIDUAL OIL	0	0	0
DISTILLATE OIL	0	0	0
NUCLEAR	5	5	5

SAI

SOLAR SYSTEM BREAK-EVEN COST FOR DIFFERENT OWNERSHIP OPTIONS
WITH GRID INTERCONNECTION TO TEXAS UTILITIES, 1990 ONLINE DATE

OWNERSHIP ALTERNATIVE	SOLAR PENETRATION LEVEL		
	2%	5%	10%
MUNICIPAL UTILITY	980	931	871
FEDERAL INSTITUTION	947	900	841
INVESTOR-OWNED UTILITY	769	731	683
25% TAX CREDIT	575	547	511
INDUSTRY BASE CASE	469	446	417
INDUSTRY WITH 50% LOAN	720	685	640
INDUSTRY WITH 5 YR. DEPR.	514	489	457
INDUSTRY WITH 20% ROI	356	338	316



LEVELIZED ANNUAL REVENUE REQUIREMENTS PER UNIT SOLAR
SYSTEM kW FOR TEXAS UTILITIES, 2000 ONLINE DATE

COST ITEM	SOLAR PENETRATION LEVEL		
	2%	5%	10%
TOTAL	79	78	73
CAPITAL	5	7	19
O&M	7	7	8
COAL	47	51	59
GAS	19	13	-13
RESIDUAL OIL	0	0	0
DISTILLATE OIL	0	0	0
NUCLEAR	1	0	0

SOLAR SYSTEM BREAKEVEN COST FOR UTILITY OWNERSHIP

SOLAR PENETRATION, %: 2 10 20
BREAKEVEN COST, \$/kW: 700 690 646




RESULTS FOR PUBLIC SERVICE OF COLORADO



ORIGINAL PAGE IS
OF POOR QUALITY

LEVELIZED ANNUAL REVENUE SAVINGS PER UNIT SOLAR
SYSTEM kW FOR COLORADO PUBLIC SERVICE, 1990 ONLINE DATE

LEVELIZED ANNUAL REVENUE SAVINGS



LEVELIZED ANNUAL REVENUE REQUIREMENTS PER UNIT SOLAR
SYSTEM kW FOR PUBLIC SERVICE OF COLORADO, 1990 ONLINE DATE

COST ITEM	SOLAR PENETRATION LEVEL		
	2%	5%	10%
TOTAL	69	66	64
CAPITAL	4	4	3
O&M	9	9	9
COAL	47	46	44
GAS	2	2	2
RESIDUAL OIL	4	4	3
DISTILLATE OIL	1	1	1
NUCLEAR	1	1	2



**SOLAR SYSTEM BREAK-EVEN COST FOR DIFFERENT OWNERSHIP OPTIONS
WITH GRID INTERCONNECTION TO PUBLIC SERVICE OF COLORADO, 1990 ONLINE DATE**

OWNERSHIP ALTERNATIVE	SOLAR PENETRATION LEVEL		
	2%	5%	10%
MUNICIPAL UTILITY	774	750	723
FEDERAL INSTITUTION	748	725	698
INVESTOR-OWNED UTILITY	608	589	567
25% TAX CREDIT	455	441	424
INDUSTRY BASE CASE	371	359	346
INDUSTRY WITH 50% LOAN	569	552	531
INDUSTRY WITH 5 YR. DEPR.	407	394	379
INDUSTRY WITH 20% ROI	281	272	262



LEVELIZED ANNUAL REVENUE REQUIREMENTS PER UNIT SOLAR
SYSTEM kW FOR PUBLIC SERVICE OF COLORADO, 2000 ONLINE DATE

COST ITEM	SOLAR PENETRATION LEVEL		
	2%	5%	10%
TOTAL	102	84	80
CAPITAL	2	2	3
O&M	9	10	11
COAL	62	62	64
GAS	20	11	11
RESIDUAL OIL	7	-2	-9
DISTILLATE OIL	0	0	0
NUCLEAR	1	2	1

SOLAR SYSTEM BREAK-EVEN COST FOR UTILITY OWNERSHIP

SOLAR PENETRATION, %:	2	10	20
BREAK-EVEN COST, \$/kW:	902	743	708




RESULTS FOR AUSTIN MUNICIPAL ELECTRIC DEPARTMENT



ORIGINAL PAGE IS
OF POOR QUALITY

LEVELIZED ANNUAL REVENUE SAVINGS PER UNIT SOLAR SYSTEM
kW FOR AUSTIN MUNICIPAL, 1990 ONLINE DATE

LEVELIZED ANNUAL REVENUE SAVINGS



LEVELIZED ANNUAL REVENUE REQUIREMENTS PER UNIT SOLAR
SYSTEM kW FOR AUSTIN MUNICIPAL, 1990 ONLINE DATE

COST ITEM	SOLAR PENETRATION LEVEL		
	2%	5%	10%
TOTAL	136	134	132
CAPITAL	0	0	0
O&M	4	4	4
COAL	4	4	5
GAS	128	126	123
RESIDUAL OIL	0	0	0
DISTILLATE OIL	0	0	0
NUCLEAR	0	0	0

ORIGINAL PAGE IS
OF POOR QUALITY

SAI

SOLAR SYSTEM BREAKEVEN COST FOR DIFFERENT OWNERSHIP OPTIONS
WITH GRID INTERCONNECTION TO AUSTIN MUNICIPAL, 1990 ONLINE DATE

OWNERSHIP ALTERNATIVE	SOLAR PENETRATION LEVEL		
	2%	5%	10%
MUNICIPAL UTILITY	1530	1515	1492
FEDERAL INSTITUTION	1477	1463	1441
INVESTOR-OWNED UTILITY	1200	1189	1170
25% TAX CREDIT	898	889	876
INDUSTRY BASE CASE	732	725	714
INDUSTRY WITH 50% LOAN	1124	1114	1096
INDUSTRY WITH 5 YR. DEPR.	803	795	783
INDUSTRY WITH 20% ROI	555	550	541



LEVELIZED ANNUAL REVENUE REQUIREMENTS PER UNIT SOLAR
SYSTEM kW FOR AUSTIN, 2000 ONLINE DATE

COST ITEM	SOLAR PENETRATION LEVEL		
	2%	5%	10%
TOTAL	115	113	109
CAPITAL	0	0	0
O&M	4	4	4
COAL	22	22	23
GAS	83	81	76
RESIDUAL OIL	0	0	0
DISTILLATE OIL	0	0	0
NUCLEAR	6	6	7

SOLAR SYSTEM BREAK-EVEN COST FOR UTILITY OWNERSHIP

SOLAR PENETRATION, %: 2 10 20
BREAK-EVEN COST, \$/kW: 1299 1277 1232




RESULTS FOR FLORIDA POWER CORPORATION



ORIGINAL PAGE IS
OF POOR QUALITY

ANNUAL ENERGY DISPLACED PER UNIT SOLAR
SYSTEM kW FOR FLORIDA UTILITY, 1990 ONLINE DATE


FLA - ENERGY DISPLACED BY SOLAR



ENERGY DISPLACED PER UNIT SOLAR SYSTEM kW
FOR FLORIDA POWER, 1990 ONLINE DATE

FUEL TYPE	PENETRATION LEVEL		
	2%	5%	10%
COAL	637	691	730
GAS	0	0	0
OIL R	285	265	234
OIL D	352	334	302
NUCLEAR	0	0	0


ORIGINAL PRINTED
OF POOR QUALITY



ORIGINAL REPORT IS
OF POOR QUALITY

LEVELIZED ANNUAL REVENUE SAVINGS FOR
FLORIDA POWER CORPORATION, 1990 ONLINE DATE

LEVELIZED ANNUAL REVENUE SAVINGS



LEVELIZED ANNUAL REVENUE REQUIREMENTS PER UNIT SOLAR
SYSTEM KW FOR FLORIDA POWER CORPORATION, 1990 ONLINE DATE

CHARGING VALUE IS
OF POOR QUALITY


COST ITEM	SOLAR PENETRATION LEVEL		
	2%	5%	10%
TOTAL	111	107	100
CAPITAL	0	0	0
O&M	4	4	4
COAL	22	24	26
GAS	0	0	0
RESIDUAL OIL	38	35	31
DISTILLATE OIL	46	44	40
NUCLEAR	0	0	0

SA

ORIGINAL REPORT
OF POOR QUALITY

BREAKEVEN SOLAR SYSTEM COST FOR DIFFERENT OWNERSHIP
OPTIONS WITH INTERCONNECTION TO FLORIDA POWER GRID,
1990 ONLINE DATE

FLA SOLAR SYSTEM BREAKEVEN COST



**SOLAR SYSTEM BREAK-EVEN COST FOR DIFFERENT OWNERSHIP OPTIONS WITH GRID
INTERCONNECTION TO FLORIDA POWER CORPORATION, 1990 ONLINE DATE**

ORIGINAL PAGE IS
OF POOR QUALITY

OWNERSHIP ALTERNATIVE	SOLAR PENETRATION LEVEL		
	2%	5%	10%
MUNICIPAL UTILITY	1250	1212	1135
FEDERAL INSTITUTION	1208	1171	1097
INVESTOR-OWNED UTILITY	981	952	891
25% TAX CREDIT	734	712	667
INDUSTRY BASE CASE	598	580	544
INDUSTRY WITH 50% LOAN	919	892	835
INDUSTRY WITH 5 YR. DEPR.	657	637	597
INDUSTRY WITH 20% ROI	454	441	412

SAI



CASE STUDY CONCLUSIONS

CONCLUSIONS

- ALL OF THE UTILITIES STUDIED ARE RAPIDLY MOVING AWAY FROM OIL AND GAS DEPENDENCE TOWARDS COAL GENERATION.
- THE VALUE OF SOLAR GENERATION IS PRIMARILY FUEL SAVINGS. CAPACITY SAVINGS ARE SMALL.
- THE VALUE OF SOLAR DECREASES AS PENETRATION INCREASES. INCREASED SOLAR PENETRATION RESULTS IN LESS OIL/GAS DISPLACEMENT AND GREATER COAL DISPLACEMENT.
- LESS THAN HALF OF THE ENERGY GENERATED BY SOLAR DISPLACES OIL AND GAS (EXCEPT FOR THE AUSTIN MUNICIPAL UTILITY IN 1990). THUS, SOLAR ELECTRIC POWER MUST ULTIMATELY COMPETE AGAINST COAL.
- THE UTILITY GENERATION MIX AND THE TYPE OF FUEL DISPLACED BY SOLAR ARE PRIMARY FACTORS IN DETERMINING SOLAR SYSTEM VALUE. SOLAR SYSTEM FINANCING ASSUMPTIONS ARE ALSO IMPORTANT.
- BREAKEVEN SOLAR SYSTEM COSTS FOR UTILITY OWNERSHIP FALL IN THE RANGE OF 700-800 \$/kW FOR TEXAS UTILITIES, 600-900 \$/kW FOR COLORADO PUBLIC SERVICE, 1300-1500 \$/kW FOR AUSTIN MUNICIPAL, AND 1100-1300 \$/kW FOR FLORIDA POWER CORPORATION. HIGHER BREAKEVEN COSTS ARE ASSOCIATED WITH GREATER OIL AND GAS DEPENDENCE.
- SOLAR SYSTEM VALUE CAN EITHER INCREASE OVER TIME AS FUEL PRICES INCREASE, OR CAN DECREASE AS COAL GENERATION IS ADDED.



SOLAR THERMAL BENEFITS STUDY

TASK 2 - R&D BENEFITS ASSESSMENT


(PARTIAL RESULTS ONLY)*

R. KING
SCIENCE APPLICATIONS, INC.
(703) 821-5788

*TASK 2 WAS TERMINATED
BY JPL RE-DIRECTION



TASK 2
METHODOLOGY APPROACH



PRELIMINARY DRAFT
R & D CONTRACT BREAKDOWN CHART
(OCTOBER 8, 1981)

TECHNOLOGY: DISH

Subsystem	Component	Objective	Quantitative Measure of Goal (Present and Future)	Duration of Contract	Contracting Organization	1980 Budget	Subsystem Percent of Total Technology Budget	Subjective Likelihood of Success	Critical or Non-critical
Storage (cont)	Stirling Storage	Dish Stirling storage requirement definition		04/80-12/80	JPL-GE	85,200	5%		
Design & Test	EE3 EE2 Shenandoah Small Community Ominum G Heliodyne Test	Thermal system engineering experiments 7 contracts			JPL	543,950 750,000 (EE2) 3,897,332 1,873,750 193,000			
Program Support		Parabolic dish workshops				6,714,082	62%		
						24,000	.02%		
					Total Program	10,881,032			

ORIGINAL PAGE IS
OF POOR QUALITY

R & D CONTRACT BREAKDOWN CHART

(NOVEMBER 12, 1981)

[illegible]

EXPLANATION OF COLUMNS:

- DATA FOR OBJECTIVE, DURATION OF CONTRACT, CONTRACTING ORGANIZATION AND BUDGET WAS OBTAINED FROM PROGRAM SUMMARY DOCUMENT
- FRACTION OF TOTAL SYSTEM COST: THIS IS THE FRACTION THAT A COMPONENT OR SUBSYSTEM IS OF THE TOTAL SYSTEM COST. RELATIVELY EASY TO ESTIMATE, HOWEVER GENERIC SYSTEMS ARE MORE DIFFICULT. AN AVERAGE SHOULD BE DETERMINED.
- HYPOTHETICAL EXAMPLE: A COLLECTOR IS 60% OF CR COST; 25% OF DISH; AND 30% OF TROUGH. THEREFORE AVERAGE WOULD BE 38%.

- APPLICABILITY TO SOLAR THERMAL SYSTEMS: THIS COLUMN ASSIGNS A PROBABILITY OF USE TO THE CONTRACT.

- MARKETS

PROBABILITY OF: ELECTRIC = $\frac{1}{2}$

- SYSTEMS

PROBABILITY OF: TROUGH = Dish = CR ($\frac{1}{3}$)

EXAMPLE: REFLECTOR TECHNOLOGY

APPLICABLE TO ALL (GENERIC) = 1.0

APPLICABLE TO ELECTRIC ONLY = ($\frac{1}{2}$)

APPLICABLE TO DISH/ELECTRIC ONLY = $\frac{1}{6}$

APPLICABLE TO CR/ELECTRIC/MOLTEN SALT = $\frac{1}{18}$
(WHERE MOLTEN SALT = SODIUM = WATER/STEAM)



EXPLANATION OF COLUMNS (CON'T.)

- LIKELIHOOD OF SUCCESS: THIS IS A SUBJECTIVE RANKING OF THE CONTRACT IN MEETING ITS' OBJECTIVE.
- QUANTITATIVE MEASUREMENT OF GOAL: THIS IS THE MAGNITUDE OF POSSIBLE COST/PERFORMANCE IMPROVEMENT DUE TO THE CONTRACT.

PRESENT PERFORMANCE (\$/KW) - POSSIBLE PERFORMANCE (\$/KW)
PRESENT PERFORMANCE (\$/KW)

(PERFORMANCE COULD ALSO BE IN \$/BTU)

BY MULTIPLYING THE LAST FOUR COLUMNS TOGETHER, A RELATIVE RANKING OF THE CONTRACTS CAN BE ACHIEVED.



THE FOLLOWING GENERIC APPROACH CAN BE USED FOR FUTURE CONTRACTS WHERE SPECIFIC

DATA IS NOT YET AVAILABLE.

<u>DISH, TROUGH, OR CR COMPONENTS</u>	<u>FRACTION OF SYSTEM COST</u>	<u>PRESENT STATE OF ART (COST/PERFORMANCE)</u>	<u>THEORITICAL/ DESIRED LIMIT (COST/PERFORMANCE)</u>	<u>TECHNICAL MATURITY</u>
---	------------------------------------	--	--	-------------------------------

COLLECTOR

RECEIVER

STRUCTURES

TRANSPORT

ETC.



EXPLANATION OF COLUMNS:

- COMPONENTS: THIS WOULD BE FILLED OUT GENERICALLY FOR THE THREE TECHNOLOGIES.
- FRACTION OF SYSTEM COST: AS STATED PREVIOUSLY.
- PRESENT STATE-OF-ART: THIS IS A PRESENT MEASUREMENT OF COST OR PERFORMANCE.
- THEORETICAL OR DESIRED LIMIT: THIS IS THE PHYSICAL OR ECONOMIC LIMIT THAT CAN BE REASONABLY ACHIEVED BY THE COMPONENT TECHNOLOGY.
EXAMPLE: MATERIALS HAVE A THEORETICAL MAXIMUM EFFICIENCY, DURABILITY, ABSORBABILITY, ETC.; AND COSTS HAVE DESIRED GOALS WHERE ANYTHING CHEAPER IS UNREASONABLE.
- TECHNICAL MATURITY: THIS SHOULD BE A RANKING SCALE WITH BASIC RESEARCH AT THE HIGH END AND COMMERCIAL AT THE LOW END. THEREFORE, BASIC OR LONG TERM R&D WILL HAVE MORE VALUE THAN TRYING TO CONTINUE R&D ON SOMETHING THAT IS COMMERCIALLY MATURE.



<u>COMPONENTS</u>	<u>FRACTION OF SYSTEM COST</u>	<u>PRESENT STATE-OF-ART (COST/PERFORMANCE)</u>	<u>THEORITICAL/ DESIRED LIMIT (COST/PERFORMANCE)</u>	<u>TECHNICAL MATURITY</u>
-------------------	------------------------------------	--	--	-------------------------------

RANKING IS CALCULATED AS FOLLOWS:

$$\begin{array}{c}
 \text{FRACTION OF} \\
 \text{SYSTEM COST}
 \end{array}
 \times
 \left[
 \begin{array}{c}
 \text{THEORITICAL} \\
 \text{LIMIT}
 \end{array}
 \right]
 \times
 \left[
 \begin{array}{c}
 \text{PRESENT} \\
 \text{STATE-OF-ART}
 \end{array}
 \right]
 \times
 \begin{array}{c}
 \text{TECHNICAL} \\
 \text{MATURITY}
 \end{array}$$



TASK 2

PRELIMINARY RESULTS FOR FY80
SOLAR THERMAL CONTRACT BREAKDOWN CHART



Subsystem	Component	Objective	Quantitative Measure (Present and Future)	Duration of Contract	Contracting Organizations	1980 Budget	Subsystem Percent of Total Technology Budget	Subjective Likelihood of Success	Critical or Non-critical
Heliostat	Mirror	Provide high performance, low life-cycle cost 2nd generation design		08/79-02/81	Sandia-Boeing Livermore	1,305,207			
	Protective Coatings	Improve wet process silver deposition procedure		10/79-09/80	SML-Battelle	140,000			
	Drive & Protective Cover	Develop protective coatings and films		12/79-02/81	SERI-Springhouse Labs	-0-			
	Foamed Glass	Fabricate cable drive system and protective cover & cleaning system		02/79-07/80	SML-Progress Industries	73,514			
		Develop a foamed glass production process		03/79-06/80	SML-Solar-amics	114,367			
		Provide high performance, low-life-cycle cost 2nd generation design		09/79-02/81	SML-Westinghouse	1,625,500			
	Solling Prevention	Develop treatments to minimize soiling and facilitate cleaning		03/79-09/80	SML-Springhouse Labs	79,443			
	Cleaning	Develop methods for cleaning without water		03/79-12/79	SML-Schmieder & Associates	21,700			
		2nd generation low-cost Heliostat production		08/79-02/81	SML-Northrup	545,993			
		Technical and economic assessment of alternative heliostat configuration		03/80-11/80	San-Veda	96,356			
						3,087,713	25%		
ORIGINAL PAGE IS OF POOR QUALITY									
Receiver		Conceptual design of high temp. receiver		08/80-10/80	JPL-GE	83,000			
		Conceptual design of high temp. receiver		01/79-12/79	JPL-Sanders	350,000			
		Conceptual design of advanced water/steam receiver		03/79-05/80	SML-Babcock Wilcox	344,235			
		Rocketdyne receiver testing support for the MDAC/CRTF		08/79-09/80	SML-McDonnell Douglas	609,012			
		10 Mw pilot plant preliminary design		03/78-03/80	San-McDonnell Douglas	-0-			
		Design molten salt central receiver		04/79-04/81	SML-Martin Mariette	418,492			
		Design molten salt central receiver		04/79-03/80	SML-GE	550,000			
		Analysis of MDAC/CRTF receiver test data		10/77-09/80	SML-Combustion Eng.	53,696			
		Analysis of MDAC/CRTF receiver test data		08/78-09/80	SML-GE	76,592			
		10 Mw pilot plant preliminary design		07/78-03/80	San-Martin Mariette	-0-			
		Design & test small heat pipe receiver module		09/79-12/80	SERI-Dynatherm	66,600			
		Advanced receiver - high temp. Steam loop experiment		03/79-07/80	SERI-Solar Turbines	62,100			
		Predictive computer program for convective losses		02/80-09/80	SML-Stanford University	22,296			

Subsystem	Component	Objective	Quant Measure Goal (1)	Contract and Fuel	Dir. of Contr.	Contract	Budget	Subst. Cent. of Technol.	Subst. of Liter.
Receiver (cont.)		Experimental investigation of convective losses Evaluation of receivers relative to two-phase hydraulic stability Investigate the application of fluidized bed technology to solar central receivers			10/79-09/80 08/77-09/80 09/79-08/80	SML-Un. of Illinois SML-Un. of Minnesota SERI-Westling-house	78,408 24,403 77,706	1983	
Transport		Molten nitrate salt electro chemical corrosion studies			05/80-05/83	SML-State Univ. at Buffalo, NY	2,818,834 15,000		
Timer		Evaluate abrasion resistance of concrete after exposure to intense solar radiation			05/79-02/80	SERI-New Mexico State U.	24,000		
Conceptual Designs Repowering/ retrofit		14 contracts			1979-07/80	San-	2,386,304	153	
Program Support		5 contracts					6,471,849	422	
							15,585,700		

ORIGINAL PAGE IS
OF POOR QUALITY

TECHNOLOGY: DISH

FY80

Subsystem	Component	Objective	Quantitative Measure (Present and Future)	Duration of Contract	Contracting Organizations	1980 Budget	Subsystem Port. Rate of Tech. Development	Subject to Likelihood of Success	Critical or Non-critical
Concentrator	-	Develop advanced low-cost point focus Fresnel lens concentrator		09/80-06/81	JPL-E-Systems.	185,000			
	-	Conceptual design of low-cost mass producible concentrator		07/79-03/81	JPL-Acurex	355,000			
	-	Develop advanced low-cost point focus concentrator using thin film		07/80-05/81	JPL-AAI Corp.	50,000			
	-	Develop advanced low-cost point focus concentrator using thin film		07/80-04/81	JPL-Boeing	100,000			
	-	Design & fabricate 3 low-cost point focus concentrators		08/79-02/81	JPL-GE	1,200,000			
	-	Design & fabricate 3 low-cost point focus concentrators		09/80-02/81	JPL-Acurex	100,000			
						1,980,000	18%		
Receiver	Air Brayton	Design and fabricate prototype solar receivers for use in Air Brayton systems		05/79-09/80	JPL-Garrett Corp.	206,000			
	Brayton	Cost analysis of a receiver for use with a Brayton engine		06/80-12/80	JPL-Pioneer Eng.	31,000			
	Steam Rankine	Design & fabricate prototype receivers for use in Steam Rankine systems		06/79-07/80	JPL-Garrett Corp.	159,000			
	Dish Stirling	Provide final assembly of dish-stirling receiver		09/80-06/81	JPL-Advance Corp.	40,000			
	Dish Stirling	Design & fabrication of dish-stirling solar receiver		03/79-09/80	JPL-Fairchild	756,000			
	Heat Pipe Solar Receiver	Design & test a heat pipe receiver with thermal energy storage		03/79-06/81	JPL-GE	250,000			
	Dish Stirling	Fabrication of dish-stirling solar receiver body		06/80-02/81	JPL-Solar Turbines Inter.	150,000			
						1,992,000	15%		
Engine/Exchanger	Turbine/Generator Stirling Engine	Develop high efficiency steam turbine		06/78-06/81	Sandia-Mechanical Tech	-0-			
		Design and analysis of 15 kWe Stirling engine		08/79-12/80	JPL-Energy Research & Generation, Inc.	8,000			
							.01%		
Storage	Rankine Storage	Dish-rankine storage power system definition		04/80-12/80	JPL-Ford Aerospace	73,750			
	Brayton Storage	Dish-brayton storage requirement definition		04/80-12/80	JPL-GE	85,000			
		Develop dish-mounted latent heat buffer storage systems		01/80-01/81	Sandia-JPL	300,000			

ORIGINAL PAGE IS OF POOR QUALITY

TECHNOLOGY DISC

1980

System Component	Objective	Quantitative Measurement of Goal (Present and Future)	Duration of Contract	Contracting Organization	1980 Budget	Subsystem Percent of Total Technology Budget	Subjective Likelihood of Success	Critical or Non-critical
Storage (unit)	Dish Stirling storage requirement definition		04/80-12/80	JPL-GE	85,200	5%		
Design & Test	Thermal system engineering experiments 7 contracts			JPL	543,950 750,000 (FE2) 3,897,332 1,873,750 193,000			
Program Support	Farabolic dish workshops				6,714,082 24,000	62%		
				Total Program	10,881,032	.02%		

ORIGINAL PAGE 19
OF POOR QUALITY.

1980

Sunsystem	Component	Objective	Quantic Measur and Future	Duration of Contract	Contract Organizat	1980 Budget	Subsyst Cent of Technology	Subst of Spec
Collector	Mirrors	Design and build ten collectors using fiber-glass structure and sagged glass		12/78-06/79	Sandia-Custom Engineering	6,000		
	Glass Molding	Provide prototype laminated thermally formed glass parabolic mirrors		08/80-02/81	Sandia-PPG Industries	49,500		
	Sagged Glass	Sheet molding trough panels with sagged glass and chemically strengthened glass		10/79-11/80	Sandia-Budd Co.	211,600		
	Sagged Glass	Understand optical and mechanical quality of mass-produced sagged glass		07/79-11/80	Sandia-Ford Aerospace	133,000		
	Glass	"same as above"		09/79-01/80	Sandia-PPG Industries	22,076	5%	
Receiver		Understand optical and mechanical quality of glass structures fabricated from high-volume metal stamping technology		10/79-12/80	Sandia-Budd Co.	229,000		
						651,276		
		Design "D" shaped receiver tube		07/80-07/81	Sandia-BOM	197,000	2%	
	Structures	Determine properties of glass fiber reinforced concrete structures		07/80-01/81	Sandia-SRI International	155,000	1%	
	Field Piping	Tradeoff studies on optimum piping configurations		03/79-12/80	Sandia-Jacobs-Del	54,950	1%	
Controls		Develop prototype hardware for field control system		04/80-06/81	Sandia-Honeywell	384,000	3%	
System Testing		Design MSSIF field layout for prototype performance evaluation		06/80-12/80	Sandia-Jacobs-Engineering	45,000		
		Serve as independent test lab. for line-focusing collectors		07/79-01/81	Sandia-Hyle Labs	51,000		
		Build large aperture trough (21-ft) for evaluation at MSSIF		07/80-07/81	Sandia-Solar Kinetics	200,000		
		Test and evaluate thermal performance of commercially available collectors		09/79-09/80	SERI-Sandia	164,000		
		5 contracts - conceptual designs		06/80-09/80	Sandia-	284,446		
MISR		27 contracts			SERI-SAN, Oak Ridge	6,499,351		
INM Demonstrations		Fixed mirror, distributed focus		09/76-11/80	Sandia-E. Systems	783,000	61%	
Crosbyton						8,026,797		
Program Support		7 contracts				3,607,668	27%	
					Total Program	13,076,691		

ORIGINAL PAGE IS
OF POOR QUALITY

ORIGINAL PAGE IS
OF POOR QUALITY

subsystem	Component	Objective	Quantitative Measurement Goal (Present and Future)	Duration of Contract	Contracting Organizations	1980 Budget	Subsystem Per Cent of Total Technology Budget	Subjective Likelihood of Success	Critical or Non-critical
collector		Evaluate various small module fixed mirror concentrator concepts	Accuracy < 3.5 mrad cost < \$1.25/rad	03/80-03/81	JPL-Univ. of Arizona	25,000	7%		
		Identify industrial site specific environmental degradation problems		03/80-03/81	SERI-DSET Labs	52,715			
		Exposure testing of reflector materials		09/77-10/80	SERI-Honeywell	25,971			
		Technical support on cellular glass program		02/80-12/80	SERI-JPL	6,900			
		Fabricate, certify, & sell reflectance standard reference materials		07/78-02/81	SERI-MBS	1,000,000			
		Develop processes to produce thermal sag and press formed glass		12/79-06/80	SERI-Suntec	-0-			
		Thin film reflective surface gauging study		07/80-12/80	JPL-Wittenburg College	15,000			
		Develop better quality mirrors		04/77-09/80	SERI-BPNL	285,000			
		Investigate optical properties of metallic surfaces, small particles and composite coatings		05/77-08/80	SERI-Cornell	-0-			
		Plastic film performance improvement		04/79-07/80	SMLL-Boeing and DSET	51,486			
receiver		Design & fab. first surface fresnel concentrator concept		09/79-05/81	JPL-Sun Power	42,621	7%		
						696,693			
		Surface morphologies of efficient solar absorbing materials		04/77-09/80	SERI-Univ. of Houston	2,000			
		Develop low-cost, high-temp. absorber points		07/77-02/80	SERI-Exxon	-0-			
		Evaluate CVD for the production of receiver coatings		02/80-02/81	SERI-Raytherm	2,000			
		Evaluate selective absorber coatings in air & vacuum to 7000C		04/78-09/80	SERI-U. of Minn.	5,000			
		Analyze thermal shock resistance of ceramic materials on solar receivers		12/79-09/80	JPL-V.P.I.	20,000			
		High temperature thermodynamic properties		01/79-07/80	SERI-U. of Kansas	28,411			
		Chemical vapor deposition of spectrally selective absorbers		05/79-09/80	SERI-U. of Arizona	80,000			
		Develop improved absorber coatings		07/79-09/80	SERI-SERI	-0-			
		Test and evaluate SO ₂ converters		05/80-11/80	JPL-New Mexico State U.	31,000			
		Develop computer code to predict convective energy loss from cavity-type receivers		10/79-09/82	SMLL-Univ. of Cal.	57,227			
		Design a solar chemical receiver for advanced applications		03/80-09/80	JPL-Westinghouse	120,167			
						345,807			

TECHNOLOGY: GENERIC SYSTEMS

TY 80

Subsystem	Component	Objective	Quant Measure (Cost and Fuel)	Duration	Contract	Contract Organs	Estimate	Subsystem Cost of Life	Subsystem Cost of Life
Heat Engine/Exchanger		Obtain 25KWe MOD-0 Brayton engine/generator set Conduct heat pipe testing for life & performance data		02/00-06/81 09/79-03/81	NASA Lewis-A. Research SAM-Bechtel		845,000 16,292 861,292	9%	
Transport		Design solar energy delivery system for IPH Design High temperature fluid loop Identify Potential high-temperature Silicon based heat transfer fluids Design a flexible fluid handling system for IPH systems Design a portable fluid loop to be used at MSTF		10/79-2/81 01/79-06/80 03/80-08/80 10/79-09/80 04/79-06/80	SERI-Barber Nichols Sandia-Custom Engineering SERI-Dow Corning SERI Sandia-Bovay Engineering		214,000 55,000 17,000 162,400 36,000 484,400	5%	
Controls/Tracking		Design tracking instrument and associated Controller		11/79-11/80	H.O.-De1 Manufacturing		156,122	1%	
Structures		Develop analytical model and code to predict foundation motion Develop interim structural design standard and evaluation creep-fatigue		07/80-03/81 04/77-03/80	SMLL-GAI SMLL-Foster Wheeler		25,000 24,083 50,000	.5%	
Storage		Demonstrate the viability of the checker stove storage module Investigate solidification control in a Eutectic Salt mixture Predict thermal performance of heat exchangers for storage of later heat in phase change materials Research underground thermal storage		11/79-10/80 TBD 05/77-09/80 05/77-09/80	JPL-Sanders SERI SERI		46,000 15,000 52,037 110,456 223,493	2%	
System Testing		Field evaluation and reliability testing Management of advanced component test facility (ACTF) Operation of MSTF		03/80-02/81 09/80-10/81 12/74 →	SERI-Hangwe SERI-Georgia Tech Sandia-E.G.G.		15,300 887,125 400,000 1,302,425	13%	

ORIGINAL PAGE IS
OF POOR QUALITY

Subsystem	Component	Objective	Quant. Measure Cont (pc and futur)	Start of Contract	Contract Organization	1981 Budget	Subsystem Cont of Technology	Subsystem Cont of Support
Materials		Properties and Durability data for solar Materials		12/79-03/81	SERI-DSET	153,700	1%	
Standards		Matrix development to define functions and standards for solar thermal processes		03/80-05/80	SERI-NUS	19,541		
Reliability		Performance data & reliability data gathering system development		08/80-10/80	SERI-NUS	19,500 39,000		
Economic Assessment		Economic assessment of advanced plants		06/79-12/80	SAN-Westing-house	129,800	1%	
Program Support		13 Contracts				5,661,313	57%	
					TOTAL Program	9,950,345		
Fuels & Chemicals		11 contracts				813,627		

TASK 2

TASK 2 PRELIMINARY RESULTS FOR FY77
SOLAR THERMAL CONTRACT BREAKDOWN CHART



Subsystem	Component	Objective	Duration of Contract	Contracting Organizations	Budget	Fraction of Total Space	Number of Subsystems	Number of Components
Collector	HelioStat	Design and develop collector subsystem for 10 Mw central receiver	6/75 - 6/78	Boeing	635,000			
		Line central receiver research study and helioStat experiment	9/76 - 9/77	FMC Corp.	126,000			
		Analyze wind effect on tower and helioStat field	6/77 - 6/78	Energy Foundation of Texas	34,000			
		Mathematical simulation of blocking and shading properties of helioStat fields	6/77 - 6/78	Energy Foundation of Texas	90,000			
		Central Receiver - Prototype HelioStat, Phase I	9/77 - 5/78	Boeing	468,420			
		Central Receiver Prototype HelioStat Study, Phase I	9/77 - 7/78	General Electric	996,574			
		Central Receiver Prototype HelioStat Study, Phase I	9/77 - 5/78	McDonnell Douglas	501,000			
		Central Receiver Prototype HelioStat Study, Phase I	11/77 - 8/78	Solaramics	170,000			
		Solar Powered Steam Generator HelioStat	12/76 -	Brookhaven	190,000			
		250 kW _x Brayton Receiver design, construction and test	7/77 - 9/78	Sanders	956,000			
Receiver		Testing of the Martin Marietta 1-MM _x Bench Cavity Receiver	4/75 - 1/78	Georgia Institute of Tech.	252,718			
	Materials	Measure absorption/emission characteristics of uncoated boiler tube steels	1/76 - 3/77	Univ. of Arizona	90,000			
	Materials	Increase absorptance of Si-metal selective absorber stacks, 0.8 to 0.9	5/76 - 6/77	Argonne Nat. Lab.	75,000			
	Materials	Materials testing and surveys for water-steam receivers and components	7/77 - 12/79	Argonne Nat. Lab.	435,000			
		Experimental study of convective losses from solar receivers	6/77 - 6/78	Univ. of ILL	55,000			
		Evaluation of solar receivers relative to two phase hydraulic stability	9/77 - 12/78	Univ. of Minnesota	47,000			

ORIGINAL PAGE IS
OF POOR QUALITY

Subsystem	Component	Objective	Duration of Contract	Contracting Organizations	Budget	Percent of Total System	Applicable System Requirements	Source of Publications	Other Comments
		Fabricate and test 1-MW _e bench model cavity receiver steam generator	1/75 - 8/76	Martin Marietta	236,000				
		Shakedown test of 1-MW _e bench model cavity receiver steam generator	10/75 - 12/76	Sandia Livermore	200,000				
Heat Exchanger		Investigation of heat pipes as extended surfaces for a gas heat exchanger	2/76 - 2/78	Dynatherm Corp.	313,142				
Structures		Develop structural design standards for central receivers and components	4/77 - 12/78	Foster-Wheeler	99,750				
System Tests and Applications	Rarstow	Technical assistance for design and construction of 10MW _e Pilot plant	3/77 - 3/78	Aerospace	1,200,000				
	Rarstow	10-MW _e Central Receiver System Phase I	3/75 - 3/77	Honeywell	2,767,000				
	Rarstow	10-MW _e Central Receiver System Phase I	5/75 - 5/77	Martin Marietta	3,229,000				
	Rarstow	10-MW _e Central Receiver System Phase I	6/75 - 6/78	McDonnell Douglas	1,944,000				
	Rarstow	Develop dynamic mathematical model of the 10-MW _e CR plant	6/76 - 6/78	Singer Co.	246,000				
		Conceptual design of Advanced CR system Phase I	9/77 - 9/78	Rockwell	613,128				
		Conceptual design of advanced CR system Phase I	9/77 - 9/78	Martin Marietta	631,000				
		Conceptual design of advanced CR system Phase I	9/77 - 9/78	General Electric					
		Conceptual design of advanced CR system Phase I	9/77 - 9/78	Boeing	619,202				
		Preliminary design of 150 kW _e deep well irrigation facility	2/77 - 8/77	Black & Veatch	312,051				
		Operation of Solar Thermal Test Facility (SITF)	Continuing	Sandia Albuq.	2,150,000				
		SITF users' association	11/76 - 11/78	Univ. of Houston	169,500				

ORIGINAL PAGE IS
OF POOR QUALITY

ORIGINAL PAGE IS
OF POOR QUALITY

FY77

TECHNOLOGY DESCRIPTION

ORIGINAL PAGE IS
OF POOR QUALITY

Subsystem	Component	Objective	Duration of Contract	Contracting Organization	Budget	Percent of Total System Cost	Remarks
Receiver		Engineering design and thermal analysis	9/77 - 9/78	NRL	120,000		
System Test and Application		Preliminary design of 150 kW _p irrigation facility	2/77 - 8/77	Honeywell	324,285		
		Determine technical and economic feasibility of point focus system	8/77 - 12/77	JPL	630,000		
	FE	Establish small power systems applications project	8/77 - 12/77	JPL	667,000		
	Shenandoah	Demonstrate total energy system at knit wear factory	6 years - 6/77	Georgia Power Co.	273,000		
	Shenandoah	Provide conceptual design for knitwear factory	5/77 - 9/77	Acurex - Aerotherm	305,000		
	Shenandoah	Provide conceptual design for knitwear factory	5/77 - 9/77	General Electric	301,000		
	Shenandoah	Provide conceptual design for knitwear factory	5/77 - 9/77	Stearns - Roger	305,000		
Lobster Plant		Solar system design for lobster plant	4/77 - 8/77	Sanders	77,608		
Crosbyton		Preliminary design and cost estimate	10/76 - 1/78	Texas Tech.	1,250,000		

Subsystem	Component	Objective	Duration of Contract	Contracting Organizations	Budget	Percent of Total System	Percent of Development	Percent of Construction	Percent of Testing
Collectors		Develop compound parabolic concentrators for use in temperature range: 400°F to 600°F	10/76-10/77	Argonne National Labs	450,000				
		Demonstrate feasibility of parabolic trough using fresnel lens.	08/77-06/78	Sun Power Corporation	91,200				
System Test and Applications	Ft. Hood	Provide conceptual design for a total energy system at Ft. Hood	05/77-09/77	TRW	317,403				
	Ft. Hood	Provide conceptual design for a total energy system at Ft. Hood	05/77-09/77	Westinghouse	316,872				
	Ft. Hood	Provide site coordination and support for Ft. Hood project.	11/76-11/77	American Tech. University	2,104,425				
	MC ³	Design and construct a solar PV conversion system for MC ³	07/77-06/79	MC ³	2,000,000				
	Irrigation	Solar powered irrigation program	02/76-	Sandia National Labs Albuquerque	2,032,000				
	Coolidge	Preliminary design, 150 kWe deep well irrigation facility	02/77-08/77	Acurex	344,850				

ORIGINAL PAGE IS
OF POOR QUALITY

Subsystem	Component	Objective	Duration of Contract	Contracting Organization	Budget	Location of Test System	Applicable Spacecraft or Satellite	Remarks or Comments
Collector	Mirror	Research and development in solar mirror, and quality assurance, performance	3/77 - 3/78	Battelle	100,000			
		Non-imaging concentrators for wide-angle collection of solar energy	7/77 - 7/78	Univ. of Chicago	300,000			
Receiver	Materials	Provide AES and ESCA profile analyses of sample films and coatings	4/77 - 4/78	Univ. of Minnesota	54,971			
	Absorbers	Develop selective absorbers of the silicon-metal "stack" type for receivers	4/76 - 4/78	Univ. of Arizona	94,630			
	Materials	Absorber surface materials workshop	7/77 - 1/78	SERI	40,000			
		Black chrome absorptive coatings process development	8/77 - 11/78	Sandia Albn.	200,000			
	Materials	Development of granular semiconductors as selective absorbers	8/77 - 8/78	RCA Labs.	100,000			
	Materials	Optimization of high temperature receiver coatings	7/77 - 5/78	Exxon	79,251			
	Materials	Develop new metal oxide absorber films	7/76 - 7/78	Engelhard Industries	254,000			
Turbine	Materials	Surface morphologies of efficient solar energy absorbing materials	6/77 - 6/78	Energy Foundation of Texas	80,000			
		Perform theoretical and experimental studies on optical properties of metal-dielectric composites	5/77 - 5/78	Cornell Univ.	160,000			
System Test and Applications		Evaluation of a two-phase turbine system for electric generation	6/76 - 10/78	B. Phase Engines	94,000			
		Solar total energy test facility	10/76 - 10/77	Sandia, Albn.	3,735,000			
		Develop and test components of distributed receiver collectors	10/76 - 10/77	Sandia, Albn.	1,680,000			
		Feasibility study of solar electric facility at Bridgeport, TX	12/77 - 6/78	Carter & Burgess	94,000			
		400 kW test facility at Georgia Institute of Technology	3/77 - 1/79	GIT	266,589			

Subproject	Component	Objective	Duration of Contract	Contracting Organizations	Budget	Percent of Total System	Contracting Organization	Contract Number	Contract Date
Market Assessment		Assessment of technical and economic feasibility of solar distillation	7/77 - 2/78	Bechtel	11,634				
		Market assessment of solar water pumping for remote areas	6/77 - 11/77	Bechtel	11,717				
		Solar irrigation systems mission analysis	3/77 - 3/78	Aerospace	250,000				
		Determine economic feasibility of using solar thermal power for H-bbs, NH	6/76 - 10/77	Univ. of Oklahoma	144,746				
		Institutional applications of solar thermal energy systems	3/77 - 3/78	Resource Planning Assoc.	357,772				
		Small power systems application analysis	3/77 - 3/78	Aerospace	250,000				
		Solar total energy systems mission analysis	3/77 - 3/78	Aerospace	500,000				
		Commercial applications of solar total energy systems	5/77 - 6/78	Atomiss Int.	247,341				
		Application analysis of solar total energy for the residential sector	4/77 - 4/78	IGT	385,228				
		Application analysis of solar total energy for the industrial sector	9/77 - 4/79	McDonnell Douglas	175,872				
Program Support		Provide technical management of DOE's solar total energy activities at Sandia Laboratory	10/76 - 10/77	Sandia Lab.	1,180,000				

ORIGINAL PAGE IS
OF POOR QUALITY